

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015553-R1  
DATE: 03/03/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Bjornstad Const.  
CODE: 2644-1  
REVISION DATE: 08/31/2023  
EXPIRATION DATE: 03/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Bjornstad Construction Company</b> <b>1240 Texan Trail, Suite 102</b> <b>Grapevine, TX 76051</b>	<b>Endura 20 Minute Category C</b> <b>Proprietary Wood Door Frames</b>  Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations  <b>Single Door Maximum Size: 3'0" x 8'0"</b>  <b>Minimum Thickness: 4-9/16"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1995)</b> <b>UL 10b (1997)(2009)</b> <b>CAN/ULC S104 (1980)(2010)</b> <b>UBC Standard 7-2 (1994)</b>	<b>20 Minute-With Hose Stream</b> <b>Neutral Pressure</b> <b>Category C- Proprietary Frame</b>

TEST REPORT
<b>Intertek Test Report No(s): J98027188-231</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)