

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015555.01  
DATE: 03/03/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Vinylmax  
CODE: 072-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Vinylmax, LLC</b> <b>2921 McBride Court</b> <b>Hamilton, OH 45011</b>	<b>Series "SHA4WW/Slope Sill"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1118mm(44") H-1905mm(75") Sash: W-1057mm(41.63") H-930mm(36.63") DLO: W-984mm(38.75") H-860mm(33.88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG40 1118 x 1905 (44 x 75)-H</b> <b>Design Pressure: ±1915 Pa (±40 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Molimo, LLC  
Report No: 11270.01-109-12  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)