

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015555  
DATE: 03/03/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Vinylmax  
CODE: 072-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Vinylmax, LLC</b><br><b>2921 McBride Court</b><br><b>Hamilton, OH 45011</b> | <b>Series "SHA4WW/Slope Sill"</b><br><b>Vinyl Single Hung Window</b><br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1118mm(44")      H-1905mm(75")<br>Sash: W-1057mm(41.63")      H-930mm(36.63")<br>DLO: W-984mm(38.75")      H-860mm(33.88") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> | <b>Class LC-PG30 1118 x 1905 (44 x 75)-H</b><br><b>Design Pressure: ±1440 Pa (±30 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A2</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> |

Product Tested By: Molimo, LLC  
Report No: 11270.01-109-12  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)