

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015557
DATE: 03/15/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Homewood
CODE: 2824-1
EXPIRATION DATE: 03/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Homewood Door Corporation 3237 Rippey Road Loomis, CA 95650	20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single and Double Swing Installation in 20 Minute Locations Single Door Maximum Size: 4'0" x 9'0" Double Door Maximum Size: 8'0" x 9'0" Minimum Thickness: 3-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (1998) UBC Standard 7-2 (1997) UBC Standard 7-2 (1994)	20 Minute-With & Without Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460 Priest & Assoc. Engineering Evaluation No: 10260 NAMI Waiver of Retest: W-1747

A handwritten signature in black ink, appearing to be 'M.D.' or similar initials.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com