

Notice of Product Certification

CERTIFICATION NO.: 1538-005

INITIAL CERTIFICATION DATE: April 27, 2022

REVISION DATE: N/A

REPORT NUMBER: SPL21005-6-C_LFIXD-H

SPECIFICATION: CSA A440.2-19

COMPANY: DV Aluminium

CODE: 1538-1

EXPIRATION DATE: March 18, 2026

PRODUCT SIMULATED BY: Veridis Solutions

AIR LEAKAGE REPORT NO.: AI-04137-I1 Rev.1

PRODUCT/SERIES NAME: Grand Fixe Hybride 9000

OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Infiltration	Air Exfiltration	Air Leakage Average (L75)	Energy Rating
1538-005-0001-01	3mm_7/8_SDCI-arg95-PTLX(0.082/#3) im	1.70	0.59	0.62	0.15	0.15	0.2	36
1538-005-0002-01	3mm_7/8_SDCI-arg95-PTLX(0.082/#3) sw	1.67	0.59	0.62	0.15	0.15	0.2	37
1538-005-0003-01	4mm_7/8_SDCIarg95-PTLX(0.081/#3) im	1.68	0.59	0.62	0.15	0.15	0.2	37
1538-005-0004-01	4mm_7/8_SDCI-arg95-PTLX(0.081/#3) sw	1.66	0.59	0.62	0.15	0.15	0.2	37
1538-005-0005-01	5mm_7/8_SDCIarg95-PTLX(0.082/#3) im	1.67	0.58	0.61	0.15	0.15	0.2	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.

4794 George Washington Memorial Hwy.

Hayes, VA 23072

Tel.: (804) 684-5124

nami@namiinc.com

namicertification.com

