

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014930.01
DATE: 04/05/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Four Seasons
CODE: 1812-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Four Seasons Solar Products, LLC 5005 Veterans Memorial Highway Holbrook, NY 11741	Series "PD12WW" Vinyl Sliding Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3569mm(140.5") H-2070mm(81.5") Panel: W-924mm(36.38") H-1991mm(78.38") DLO: W-806mm(31.75") H-1873mm(73.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMACSA 101/I.S.2/A440-08	Class R-PG25 3569 x 2070 (141 x 82)-SD Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 220 Pa(4.60 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D3116.01-501-47
Expiration Date: August 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com