

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015560  
**DATE:** 04/06/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia Door  
**CODE:** 1212-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia, LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>Legacy 20 Gauge Steel Smooth Full-Lite</b> <b>Inswing Single Entry Door</b>  (w/ODL Evolve Trim & Modified Lock Block)  Configuration: X Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090' Saflex PVB Interlayer/1/8" Annealed Glass  Frame: W-954mm(37.56") H-2481mm(97.69") Panel: W-908mm(35.75") H-2413mm(95") DLO: W-530mm(20.88") H-2003mm(78.88")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: N2641.01-501-47/NCTL-110-15660-2  
Expiration Date: **January 31, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)