

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015561
DATE: 04/07/2022
CERTIFICATION PROGRAM: Structural
COMPANY: VTECH
CODE: 2838-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VTECH Industries L.P. 5534 Harvey Wilson Drive Houston, TX 77020	4 x 4 CMC Hurricane Glass Skylight Configuration: O Glazing: IG-5/32" Tempered Glass/3/32" Heat Strengthened Glass/0.120' DuPont Butacite PVB Interlayer/3/32" Heat Strengthened Glass Frame: W-1302mm(51.25") H-1302mm(51.25") DLO: W-1276mm(50.25") H-1276mm(50.25")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-05 ASTM E1996-05	SKG-C55 1302 x 1302 (51 x 51) Design Pressure: ±2640 Pa (±55 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Wind Zone 4 - Missile Level D

Product Tested By: Architectural Testing Inc.
Report No: 92239.01-801-18/92239.06-801-44
Expiration Date: April 30, 2026

Administrator's Signature: _____


**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com