

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015566-R1
DATE: 04/18/2022
CERTIFICATION PROGRAM: Fire
COMPANY: Truitt & White
CODE: 2807-1
REVISION DATE: 04/07/2026
EXPIRATION DATE: 04/30/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Truitt & White Lumber Company, Inc. 642 Hearst Avenue Berkeley, CA 94710	Trimlite 20 Minute Wood Panel Fire Door Assembly Manufacturer Specific Fire Doors for Single, Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw for Singles 3-Point Latching Hardware Required for Doubles Single & Double Swing Only Single Maximum Size: 3'0" x 8'0" Double Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10C (2016) UL 10B (R2015) CAN/ULC S104 (2015)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Steel Stud, Wood Stud w/Gypsum Sheathing or Masonry Wall Applications (In accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 1002955115COQ-002/1002955115COQ-002a/3158685-005

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

