

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015566  
DATE: 04/18/2022  
CERTIFICATION PROGRAM: Fire  
COMPANY: Truitt & White  
CODE: 2807-1  
EXPIRATION DATE: 04/30/2026

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Truitt &amp; White Lumber Company, Inc.</b>  <b>642 Hearst Avenue</b>  <b>Berkeley, CA 94710</b>	<b>Trimlite 20 Minute Wood Panel</b>  <b>Fire Door Assembly</b>  Manufacturer Specific Fire Doors for Single, Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw for Singles 3-Point Latching Hardware Required for Doubles Single & Double Swing Only  <b>Single Maximum Size: 3'0" x 8'0"</b> <b>Double Maximum Size: 6'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10C (2016)</b> <b>UL 10B (R2015)</b> <b>CAN/ULC S104 (2015)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> <b>For Use in Steel Stud, Wood Stud w/Gypsum Sheathing</b> <b>or Masonry Wall Applications</b> <b>(In accordance with individual manufacturer's listing)</b>

TEST REPORT
<b>Intertek Test Report No: 1002955115COQ-002/1002955115COQ-002a/3158685-005</b>

A handwritten signature in black ink, appearing to be "S. H. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)