NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI015574**
DATE:	**04/20/2022**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Gem State**
CODE:	**2403-1**
EXPIRATION DATE:	**04/30/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gem State Doors & Millwork **608 Carnation Drive** **Nampa, ID 83653**	**Rogue Valley 20 Minute** **Positive Pressure MDF** **Side-Hinged Door Assembly** Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only **Single Maximum Size: 3'6" x 8'0"** **Double Maximum Size: 7'0" x 8'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
UBC-7-2-97 **UL 10C (1998)(2009)** **NFPA 252 (1999)** **CAN4 S104 (1985)** **CAN/ULC S104 (2010)**	**20 Minute-Positive Pressure w/Hose Stream** **Category A Door-No Additional Edge Seal Required** **For Use in Category C Frame** (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3049231/3049231a

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com