

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014012-R2
DATE: 04/04/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Gator Build Sup
CODE: 2152-1
REVISION DATE: 03/17/2026
EXPIRATION DATE: 04/30/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gator Building Supply, Inc. 9555 North US 1 Sebastian, FL 32958	20 Minute Positive & Neutral Pressure Flush or Molded Interior Side-Hinged Door w/Particleboard Core Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10(b) (2009) ASTM E2074 (2000) CAN4-S104(ULC S104) UBC Standard 7-2 (1994/1997) UL 10(c) (1998)	20 Minute-Neutral/Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3137713COQ-007


 Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com