

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014051-R1  
**DATE:** 05/08/2018  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Gator Build Sup  
**CODE:** 2152-1  
**REVISION DATE:** 05/03/2022  
**EXPIRATION DATE:** 05/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Gator Building Supply, Inc.</b> <b>9555 North US 1</b> <b>Sebastian, FL 32958</b>	<b>JM Eagle 20 Minute Category C</b> <b>Proprietary Wood Composite</b> <b>Door Frames w/PVC Cladding</b>  Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations (Particle Board Core Wood, Fiberglass Skin, Steel Skin w/ Wood Edged Doors Only)  Wood & Fiberglass Single Door Maximum Size: 3'0" x 8'0" Steel w/Wood Edge Single Door Maximum Size: 3'0" x 7'0"  <b>Minimum Thickness: 4-1/2"</b>

SPECIFICATION	PRODUCT RATING
<b>CAN4 S104 (1985)(2010)</b> <b>NFPA 252 (2008)(2012)</b> <b>UL 10C (2001)(2009)</b>	<b>20 Minute-Without Hose Stream</b> <b>Positive Pressure</b> <b>Category C- Proprietary Frame</b>
TEST REPORT	
<b>Intertek Test Report No(s): 3167720MID-004, 3167700MID-013, 3183953MID-001, 100142215MID-002b, 100529924MID-002R1, 101729929-001</b>	

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)