

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI014052-R1</u>
DATE:	<u>05/08/2018</u>
CERTIFICATION PROGRAM:	<u>Fire</u>
COMPANY:	<u>Gator Build Sup</u>
CODE:	<u>2152-1</u>
REVISION DATE:	<u>05/03/2022</u>
EXPIRATION DATE:	<u>05/31/2026</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Gator Building Supply, Inc.</p> <p>9555 North US 1</p> <p>Sebastian, FL 32958</p>	<p style="text-align: center;">JM Eagle 20 Minute Category C</p> <p style="text-align: center;">Proprietary Wood Composite</p> <p style="text-align: center;">Door Frames w/PVC Cladding</p> <p style="text-align: center;">Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations (Particle Board Core Wood & Fiberglass Skin Doors Only)</p> <p style="text-align: center;">Single Door Maximum Size: 3'0" x 8'0"</p> <p style="text-align: center;">Minimum Thickness: 4-1/2"</p>

SPECIFICATION	PRODUCT RATING
<p>CAN4 S104 (1985)(2010)</p> <p>NFPA 252 (2008)(2012)</p> <p>UL 10C (2001)(2009)</p>	<p>20 Minute-With Hose Stream</p> <p>Positive Pressure</p> <p>Category C- Proprietary Frame</p>

TEST REPORT
<p>Intertek Test Report No(s): 3167720MID-004, 3167700MID-013, 3183953MID-001, 100142215MID-002b, 100529924MID-002R1, 101729929-001</p>

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com