

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015165.01
DATE: 05/04/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "4400-T Pivot Door" Impact Resistant Aluminum Pivot Door Configuration: X Glazing: Mono-1/4" Heat Strengthened Glass/0.090 Sentryglas Interlayer/1/4" Heat Strengthened Glass IG-1/4" Heat Strengthened Glass/0.090 Sentryglas Interlayer/1/4" Heat Strengthened Glass/1/4" Tempered Glass Frame: W-1829mm(72") H-3048mm(120") DLO: W-1568mm(61.75") H-2772mm(109.13")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a ASTM E1996-14a	Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01993413
Expiration Date: November 30, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com