NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015555.05

DATE: 05/02/2022

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Vinylmax</u>

CODE: <u>072-1</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vinylmax, LLC	Series "SHA4WW"
2921 McBride Court	Vinyl Twin Single Hung Window
Hamilton, OH 45011	
	Configuration: O/XO/X Glazing: Insulating Glass (Annealed)
	Frame: W-2248mm(88.50") H-1905mm(75")
	Sash: W-1057mm(41.63") H-930mm(36.63")
	DLO: W-987mm(38.88") H-860mm(33.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG25 2248 x 1905 (89 x 75)-H Design Pressure: ±1200 Pa (±25 psf)
AAMA/WDMA/CSA 101/1.5.2/A440-11	Canadian Air Infiltration/Exfiltration Level: A2 Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 11348.02-109-12
Expiration Date: March 31, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Email: nami@namiinc.com