

# Notice of Product Certification

**CERTIFICATION NO.:** 1356-003  
**INITIAL CERTIFICATION DATE:** June 30, 2022  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL21004-26-C\_CSSV-H  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** Portes & Fenetres Ebi-Tech, Inc.  
**CODE:** 1356-1  
**EXPIRATION DATE:** October 25, 2026  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-03741-X1 Rev.2

**PRODUCT/SERIES NAME:** Battant - Hybride - 9000    **OPERATOR TYPE:** CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1356-003-0001-01	GL   3mm_1 1/4_PCl-arg95-PCl-arg95-8071   iu	0.082(#5)	1.28	0.43	0.48	0.1	37
1356-003-0002-01	GL   3mm_1 1/4_PCl-arg95-PCl-arg95-8071   iu   Grids<1"	0.082(#5)	1.28	0.39	0.44	0.1	34
1356-003-0003-01	GL   3mm_1 1/4_PCl-arg95-PCl-arg95-8071   iu   Grids>1"	0.082(#5)	1.28	0.36	0.39	0.1	33
1356-003-0004-01	GL   3mm_7/8_PCl-arg95-SG400   su	0.113(#3)	1.58	0.47	0.52	0.1	32
1356-003-0005-01	GL   3mm_7/8_PCl-arg95-8071   su	0.082(#3)	1.54	0.48	0.53	0.1	34
1356-003-0006-01	GL   3mm_7/8_PLUX-arg90-PTLX   su	0.082(#3)	1.55	0.48	0.52	0.1	34
1356-003-0007-01	GL   3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX   su	0.082(#5)	1.24	0.44	0.48	0.1	38
1356-003-0008-01	GL   3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX   su   Grids<1"	0.082(#5)	1.24	0.40	0.43	0.1	36
1356-003-0009-01	GL   3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX   su   Grids>1"	0.082(#5)	1.24	0.36	0.39	0.1	33
1356-003-0010-01	GL   3mm_1 1/4_PTLX-arg90-PLUX-arg90-PTLX   su	0.082(#2, 5)	1.06	0.39	0.46	0.1	39
1356-003-0011-01	GL   3mm_1 1/4_PTLX-arg90-PLUX-arg90-PTLX   su   Grids<1"	0.082(#2, 5)	1.08	0.36	0.41	0.1	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.  
 4794 George Washington Memorial Hwy.  
 Hayes, VA 23072  
 Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)

