

Notice of Product Certification

CERTIFICATION NO.: 2801-005
INITIAL CERTIFICATION DATE: May 19, 2022
REVISION DATE: N/A
REPORT NUMBER: SPL21005-7-C_SFIXD-P_PFC
SPECIFICATION: CSA A440.2-19

COMPANY: PF Concordia W + D, Inc.
CODE: 2801-1
EXPIRATION DATE: December 10, 2025
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03741-C1 Rev.4

PRODUCT/SERIES NAME: Petite Fixe PVC

OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2801-005-0001-01	3mm_7/8_SDCI-arg90-PTLX(0.082/#3) sw	1.61	0.64	0.67	0.0	42
2801-005-0002-01	3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.082/#5) sw	1.23	0.56	0.61	0.0	45
2801-005-0003-01	3mm_7/8_PLUX-arg90-PTLX(0.082/#3) sw	1.61	0.62	0.67	0.0	41
2801-005-0004-01	3mm_1 1/4_PTLX(0.082/#2)-arg90-PLUX-arg90-PTLX(0.082/#5) sw	0.99	0.50	0.59	0.0	47
2801-005-0005-01	4mm_7/8_PLUX-arg90-PTLX(0.081/#3) sw	1.59	0.60	0.66	0.0	40
2801-005-0006-01	4mm_7/8_SDCI-arg90-PTLX(0.081/#3) sw	1.59	0.63	0.67	0.0	42
2801-005-0007-01	4mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.081/#5) sw	1.30	0.54	0.60	0.0	43
2801-005-0008-01	4mm_1 1/4_PTLX(0.081/#2)-arg90-PLUX-arg90-PTLX(0.081/#5) sw	1.07	0.49	0.57	0.0	45
2801-005-0009-01	3mm_7/8_GCI-arg95-8071(0.082/#3) sp	1.60	0.60	0.67	0.0	40
2801-005-0010-01	4mm_7/8_GCI-arg95-8071(0.082/#3) sp	1.57	0.59	0.67	0.0	40

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.' or similar, written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com