

# Notice of Product Certification

**CERTIFICATION NO.:** 2801-006  
**INITIAL CERTIFICATION DATE:** May 19, 2022  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL21005-7-C\_LFIXD-P\_PFC  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** PF Concordia W + D, Inc.  
**CODE:** 2801-1  
**EXPIRATION DATE:** March 18, 2026  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-03741-B1 Rev.3

**PRODUCT/SERIES NAME:** Grand Fixe PVC

**OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2801-006-0001-01	3mm_7/8_SDCI-arg90-PTLX(0.082/#3)   sw	1.60	0.59	0.62	0.0	39
2801-006-0002-01	3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.082/#5)   sw	1.24	0.51	0.56	0.0	42
2801-006-0003-01	3mm_7/8_PLUX-arg90-PTLX(0.082/#3)   sw	1.60	0.57	0.62	0.0	38
2801-006-0004-01	3mm_1 1/4_PTLX(0.082/#2)-arg90-PLUX-arg90-PTLX(0.082/#5)   sw	1.03	0.46	0.54	0.0	44
2801-006-0005-01	4mm_7/8_PLUX-arg90-PTLX(0.081/#3)   sw	1.58	0.56	0.61	0.0	38
2801-006-0006-01	4mm_7/8_SDCI-arg90-PTLX(0.081/#3)   sw	1.58	0.59	0.62	0.0	39
2801-006-0007-01	4mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.081/#5)   sw	1.31	0.50	0.55	0.0	40
2801-006-0008-01	4mm_1 1/4_PTLX(0.081/#2)-arg90-PLUX-arg90-PTLX(0.081/#5)   sw	1.09	0.45	0.53	0.0	42
2801-006-0009-01	3mm_7/8_GCI-arg95-8071(0.082/#3)   sp	1.59	0.55	0.62	0.0	37
2801-006-0010-01	4mm_7/8_GCI-arg95-8071(0.082/#3)   sp	1.57	0.54	0.62	0.0	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.' or similar, written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com