

Notice of Product Certification

CERTIFICATION NO.: 2801-013
INITIAL CERTIFICATION DATE: June 2, 2022
REVISION DATE: N/A
REPORT NUMBER: SPL21004-17-C_PRAW-A
SPECIFICATION: CSA A440.2-19

COMPANY: PF Concordia W + D, Inc.
CODE: 2801-1
EXPIRATION DATE: October 25, 2025
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04647-B1

PRODUCT/SERIES NAME: Auvent-Aluminium-9000

OPERATOR TYPE: PRAW

Product Number	Manufacturer Product Code	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2801-013-0001-01	3mm_7/8_PLUX-arg90-PTLX(0.082/#3), su	1.73	0.49	0.52	0.3	30
2801-013-0002-01	3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.082/#5), su	1.39	0.44	0.48	0.3	34
2801-013-0003-01	3mm_1 1/4_PTLX(0.082/#2)-arg90-PLUX-arg90-PTLX(0.082/#5), su	1.19	0.39	0.46	0.3	36
2801-013-0004-01	3mm_7/8_SDCI-arg90-PTLX(0.082/#3), su	1.73	0.50	0.53	0.3	30
2801-013-0005-01	4mm_7/8_PLUX-arg90-PTLX(0.081/#3), su	1.72	0.48	0.51	0.3	29
2801-013-0006-01	4mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.081/#5), su	1.46	0.43	0.47	0.3	32
2801-013-0007-01	4mm_1 1/4_PTLX(0.081/#2)-arg90-PLUX-arg90-PTLX(0.081/#5), su	1.27	0.38	0.45	0.3	34
2801-013-0008-01	4mm_7/8_SDCI-arg90-PTLX(0.081/#3), su	1.72	0.50	0.52	0.3	31
2801-013-0009-01	3mm_7/8_GCI-arg95-8071(0.082/#3), sp	1.71	0.47	0.53	0.3	29
2801-013-0010-01	4mm_7/8_GCI-arg95-8071(0.082/#3), sp	1.70	0.46	0.52	0.3	29

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.
 4794 George Washington Memorial Hwy.
 Hayes, VA 23072
 Tel.: (804) 684-5124
 nami@namiinc.com
 namicertification.com