

Notice of Product Certification

CERTIFICATION NO.: 2801-014
INITIAL CERTIFICATION DATE: June 2, 2022
REVISION DATE: June 13, 2023
REPORT NUMBER: SPL21004-17-C_LFIXD-A
SPECIFICATION: CSA A440.2-19

COMPANY: PF Concordia W + D, Inc.
CODE: 2801-1
EXPIRATION DATE: October 25, 2025
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-04647-D1

PRODUCT/SERIES NAME: Grand Fixe-Aluminium-9000 **OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2801-014-0001-01	3mm_7/8_PLUX-arg90-PTLX(0.082/#3), su	1.67	0.57	0.62	0.2	36
2801-014-0002-01	3mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.082/#5), su	1.28	0.51	0.56	0.2	41
2801-014-0003-01	3mm_1 1/4_PTLX(0.082/#2)-arg90-PLUX-arg90-PTLX(0.082/#5), su	1.06	0.46	0.54	0.2	43
2801-014-0004-01	3mm_7/8_SDCI-arg90-PTLX(0.082/#3), su	1.67	0.59	0.62	0.2	37
2801-014-0005-01	4mm_7/8_PLUX-arg90-PTLX(0.081/#3), su	1.66	0.56	0.61	0.2	36
2801-014-0006-01	4mm_1 1/4_PLUX-arg90-PLUX-arg90-PTLX(0.081/#5), su	1.36	0.50	0.55	0.2	39
2801-014-0007-01	4mm_1 1/4_PTLX(0.081/#2)-arg90-PLUX-arg90-PTLX(0.081/#5), su	1.14	0.45	0.53	0.2	41
2801-014-0008-01	4mm_7/8_SDCI-arg90-PTLX(0.081/#3), su	1.66	0.59	0.62	0.2	37
2801-014-0009-01	3mm_7/8_GCI-arg95-8071(0.082/#3), sp	1.65	0.55	0.62	0.2	35
2801-014-0010-01	4mm_7/8_GCI-arg95-8071(0.082/#3), sp	1.64	0.54	0.62	0.2	35
2801-014-0011-01	6mm_7/8_366-arg95-PCI su	1.55	0.22	0.48	0.2	18

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com

