

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011888-R1
DATE: 03/10/2014
CERTIFICATION PROGRAM: Structural
COMPANY: MIM Solutions
CODE: 2034-1
REVISION DATE: 06/07/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MIM Risk Solutions, Inc. 11220 Metro Parkway, Suite 22 Ft. Myers, FL 33966	"Direct Wall Aluminum Roll Shutter-In-A-Box" Aluminum Roll-Up Shutter System Configuration: X Frame: W-5921mm(233.13") H-2387mm(94.0") Slat: W-5816mm(229.00")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only)	Design Pressure: 1915 Pa (40 psf) Negative Design Pressure: 1915 Pa (40 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3928-01
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122