

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015590.01
DATE: 05/24/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Advent
CODE: 2841-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Advent Windows & Doors, LLC 2731 East Highway 199 Springtown, Texas 76082	Series "Ascend Single Hung" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-962mm(37.88") H-775mm(30.50") DLO: W-902mm(35.50") H-717mm(28.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG35 1016 x 1600 (40 x 63)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf)

Product Tested By: Molimo, PLC
Report No: 2993.03-109-12
Expiration Date: May 31, 2026

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Molimo', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com