

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015591.03
DATE: 05/25/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Advent
CODE: 2841-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Advent Windows & Doors, LLC 2731 East Highway 199 Springtown, Texas 76082 | Series "Ascend Picture Window" Vinyl Integral Mulled Twin Fixed Window Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-2121mm(83.50") DLO: W-787mm(31") H-2007mm(79") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class R-PG50 1816 x 2121 (72 x 84)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed |

Product Tested By: Molimo, PLC
Report No: 2499.03-109-12
Expiration Date: May 31, 2026

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com