

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015595
DATE: 05/31/2022
CERTIFICATION PROGRAM: Fire
COMPANY: JELD-WEN
CODE: 1822-1
EXPIRATION DATE: 05/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "HM Surelock 4-9/16" 20 Minute Category C Proprietary PVC Door Frame Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 952mm x 2438mm Minimum Thickness: 116mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10(b) (2009) UBC Standard 7-2 (1997) UL 10(c) (2009)	20 Minute-Positive Pressure 20 Minute-Neutral Pressure Without Hose Stream Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No: 170410011SHF-BP-1

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com