

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI015600
DATE:	06/09/2022
CERTIFICATION PROGRAM:	Fire
COMPANY:	Truitt & White
CODE:	2807-1
EXPIRATION DATE:	06/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Truitt & White Lumber Company, Inc.</p> <p>642 Hearst Avenue</p> <p>Berkeley, CA 94710</p>	<p>Frame Madeiras Especiais Raised & Flat Panel MDF Fire Door Assembly</p> <p>Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single Swing Only</p> <p>Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>UL 10C (2016) NFPA 252 (2017)</p>	<p>20 Minute-Positive Pressure Without Hose Stream</p> <p>Category B Door-Additional Edge Seal Required</p> <p>For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small></p>

TEST REPORT
<p>Intertek Test Report No: 103898617MID-005R1</p>

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com