

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015606.05  
**DATE:** 06/20/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Steves and Sons  
**CODE:** 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Steves and Sons Corporation</b> <b>203 Humble Avenue</b> <b>San Antonio, TX 78225</b>	<b>Series "Regency"</b> <b>Glazed Inswing Fiberglass</b> <b>Side-Hinged Door Assembly</b> <b>(w/Sidelites)</b>  Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1740mm(68.50") H-2070mm(81.50") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-533mm(21") H-1194mm(47")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01523494 (Specimen 17)  
Expiration Date: May 31, 2026

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)