

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015607.04  
DATE: 06/21/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Steves and Sons  
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Steves and Sons Corporation</b> <b>203 Humble Avenue</b> <b>San Antonio, TX 78225</b>	<b>Series "Regency"</b> <b>Glazed Outswing Fiberglass</b> <b>Side-Hinged Door Assembly</b>  Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-953mm(37.50") H-2051mm(80.75") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-368mm(14.50") H-978mm(38.50")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04</b> <b>ASTM E330-14</b> <b>ASTM E331-00</b>	<b>Design Pressure: ±3120 Pa (±65 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01523494 (Specimen 27)  
Expiration Date: May 31, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)