

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015608.01
DATE: 06/21/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Steves and Sons Corporation 203 Humble Avenue San Antonio, TX 78225 | Series "Regency" Glazed Outswing Fiberglass Side-Hinged Door Assembly (w/Sidelites & Transom) Configuration: O/OXO Glazing: Insulating Glass (Tempered) Frame: W-1740mm(68.50") H-2400mm(94.50") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-533mm(21") H-111mm(4.38") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| ASTM E283-04 ASTM E330-14 ASTM E331-00 | Design Pressure: ±2160 Pa (±45 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) |

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01523494 (Specimen 22)
Expiration Date: May 31, 2026

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.M.', is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com