

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015609-R1
DATE: 06/21/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	Aluminum Clad Inswing Wood Impact French Door Configuration: XX Glazing: IG - 5/32" Annealed Glass/0.090" Dupont PVB Interlayer/5/32" Annealed Glass/5/32" Tempered Glass Frame: W-1829mm(72") H-2438mm(96") Panel: W-902mm(34.88") H-2384mm(93.88") DLO: W-657mm(25.88") H-2041mm(80.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG55 1829 x 2438 (72 x 96)SHD Design Pressure: ±3120 Pa(±65 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: D8180.01-201-44
Expiration Date: **June 30, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023