

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015609.01-R1  
**DATE:** 06/21/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Loewen  
**CODE:** 1862-1  
**REVISION DATE:** 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Loewen</b> <b>77 Highway 52 West</b> <b>Steinbach, Manitoba R5G 1B2</b>	<b>Aluminum Clad Inswing</b> <b>Wood Impact French Door</b>  Configuration: XX Glazing: IG - 5/32" Annealed Glass/0.090" Dupont PVB Interlayer/5/32" Annealed Glass/5/32" Tempered Glass  Frame: W-1829mm(72")      H-2438mm(96") Panel: W-902mm(34.88")      H-2384mm(93.88") DLO: W-657mm(25.88")      H-2041mm(80.38")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05</b> <b>ASTM E1996-12</b>	<b>Design Pressure: 2640 Pa(55 psf)</b> <b>Positive Design Pressure: 2640 Pa(55 psf)</b> <b>Negative Design Pressure: 3120 Pa(65 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: D8180.02-201-44  
Expiration Date: June 30, 2027

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023