

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015611  
DATE: 06/27/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Sunset Windows  
CODE: 2348-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sunset Windows and Doors, LLC</b> <b>910 Warehouse Road, Unit 110104</b> <b>Orlando, FL 32803</b>	<b>Series "V-750"</b> <b>Vinyl Horizontal Sliding Window</b> <b>(Thru-Frame w/1.25" Sill Riser)</b>  Configuration: OX Glazing: Mono-3/16" Heat Strengthened Glass/0.090 Trosifol PVB by Kuraray/3/16" Heat Strengthened Glass IG-5/32" Tempered Glass/ 5/32" Heat Strengthened Glass/0.090 PVB by Kuraray/5/32" Heat Strengthened Glass  Frame: W-1880mm(74") H-1829mm(72") Sash: W-965mm(38") H-1778mm(70") DLO: W-762mm(30") H-1588mm(62.50")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: ±2880 Pa (±60 psf)</b> <b>Water Penetration Resistance Level: 431 Pa (9.00 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4227-04  
Expiration Date: February 28, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)