

Notice of Product Certification

CERTIFICATION NO.: 2847-003

INITIAL CERTIFICATION DATE: July 26, 2022

REVISION DATE: August 15, 2022

REPORT NUMBER: SPL21005-14-C_LFIXD-P

SPECIFICATION: CSA A440.2-19

COMPANY: Enertec Window Systems

CODE: 2847-1

EXPIRATION DATE: March 18, 2027

PRODUCT SIMULATED BY: Veridis Solutions

AIR LEAKAGE REPORT NO.: AI-03741-B1 Rev.3

PRODUCT/SERIES NAME: Large Fixed PVC OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2847-003-0001-01	3mm_7/8_180-arg97-CCI cu	0.068(#2)	1.61	0.50	0.61	0.0	34
2847-003-0002-01	3mm_7/8_180-arg97-CCI cu Grids<1"	0.068(#2)	1.61	0.45	0.55	0.0	31
2847-003-0003-01	3mm_1 1/4_180-arg97-CCI-arg97-180 cu	0.068(#2, #5)	1.02	0.44	0.54	0.0	43
2847-003-0004-01	3mm_1 1/4_180-arg97-CCI-arg97-180 cu Grids<1"	0.068(#2, #5)	1.02	0.39	0.48	0.0	40
2847-003-0005-01	3mm_1 1/4_8071-arg95-GCI-arg95-8071, ss	0.082(#2, #5)	1.03	0.46	0.55	0.0	44
2847-003-0006-01	3mm_7/8_GCI-arg95-8071, ss	0.082(#3)	1.59	0.55	0.62	0.0	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.

4794 George Washington Memorial Hwy.

Hayes, VA 23072

Tel.: (804) 684-5124

nami@namiinc.com

namicertification.com