

# Notice of Product Certification

CERTIFICATION NO.: 2847-004

COMPANY: Enertec Window Systems

INITIAL CERTIFICATION DATE: July 26, 2022

CODE: 2847-1

REVISION DATE: August 15, 2022

EXPIRATION DATE: March 18, 2027

REPORT NUMBER: SPL21005-14-C\_SFIXD-P

PRODUCT SIMULATED BY: Veridis Solutions

SPECIFICATION: CSA A440.2-19

AIR LEAKAGE REPORT NO.: AI-03741-C1 Rev.4

PRODUCT/SERIES NAME: Small Fixed PVC OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2847-004-0001-01	3mm_7/8_180-arg97-CCI   cu	0.068(#2)	1.61	0.54	0.66	0.0	36
2847-004-0002-01	3mm_7/8_180-arg97-CCI   cu   Grids<1"	0.068(#2)	1.61	0.49	0.59	0.0	33
2847-004-0003-01	3mm_1 1/4_180-arg97-CCI-arg97-180   cu	0.068(#2, #5)	0.99	0.47	0.59	0.0	45
2847-004-0004-01	3mm_1 1/4_180-arg97-CCI-arg97-180   cu   Grids<1"	0.068(#2, #5)	0.99	0.43	0.52	0.0	43
2847-004-0005-01	3mm_1 1/4_8071-arg95-GCI-arg95-8071, ss	0.082(#2, #5)	1.00	0.49	0.60	0.0	46
2847-004-0006-01	3mm_7/8_GCI-arg95-8071, ss	0.082(#3)	1.60	0.60	0.67	0.0	40

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.

4794 George Washington Memorial Hwy.

Hayes, VA 23072

Tel.: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

[namicertification.com](http://namicertification.com)