

Notice of Product Certification

CERTIFICATION NO.: 2853-006

INITIAL CERTIFICATION DATE: July 28, 2022

REVISION DATE: N/A

REPORT NUMBER: SPL21004-18-C_LFIXD-A

SPECIFICATION: CSA A440.2-19

COMPANY: Fenêtres Uniques Windows Inc.

CODE: 2853-1

EXPIRATION DATE: October 25, 2026

PRODUCT SIMULATED BY: Veridis Solutions

AIR LEAKAGE REPORT NO.: AI-04647-D1

PRODUCT/SERIES NAME: Grand Fixe - Aluminium - 9000 OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2853-006-0001-01	3mm_7/8_GCI-arg90-8071 ss	0.082(#3)	1.69	0.55	0.62	0.2	34
2853-006-0002-01	3mm_7/8_GCI-arg90-8071 ss Grids <1"	0.082(#3)	1.69	0.50	0.55	0.2	31
2853-006-0003-01	3mm_1 1/4_GCI-arg90-GCI-arg90-8071 ss	0.082(#5)	1.31	0.50	0.57	0.2	40
2853-006-0004-01	3mm_1 1/4_GCI-arg90-GCI-arg90-8071 ss Grids <1"	0.082(#5)	1.32	0.45	0.51	0.2	37
2853-006-0005-01	GL 3mm_1 1/4_PCI-arg97-PCI-arg97-PTLX ms	0.082(#5)	1.30	0.52	0.57	0.2	41

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.

4794 George Washington Memorial Hwy.

Hayes, VA 23072

Tel.: (804) 684-5124

nami@namiinc.com

namicertification.com