

# Notice of Product Certification

CERTIFICATION NO.: 2853-008  
INITIAL CERTIFICATION DATE: July 28, 2022  
REVISION DATE: N/A  
REPORT NUMBER: SPL21004-18-C\_PRAW-P  
SPECIFICATION: CSA A440.2-19

COMPANY: Fenêtres Uniques Windows Inc.  
CODE: 2853-1  
EXPIRATION DATE: October 25, 2026  
PRODUCT SIMULATED BY: Veridis Solutions  
AIR LEAKAGE REPORT NO.: AI-04490-A1 Rev.1

PRODUCT/SERIES NAME: Auvent - PVC

OPERATOR TYPE: PRAW

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2853-008-0001-01	3mm_7/8_GCl-arg90-8071   ss	0.082(#3)	1.51	0.47	0.53	0.1	34
2853-008-0002-01	3mm_7/8_GCl-arg90-8071   ss   Grids<1"	0.082(#3)	1.51	0.43	0.47	0.1	32
2853-008-0003-01	3mm_1 1/4_GCl-arg90-GCl-arg90-8071   ss	0.082(#5)	1.20	0.42	0.48	0.1	38
2853-008-0004-01	3mm_1 1/4_GCl-arg90-GCl-arg90-8071   ss   Grids<1"	0.082(#5)	1.20	0.38	0.43	0.1	35

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com