

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015368.04
DATE: 07/18/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74th Place Hialeah, FL 33014	Series "5000" Aluminum Single Hung Window Configuration: O/X/OO/X/O Glazing: Monolithic: - 1/4" Tempered Glass/0.060" Saflex/Keepsafe Maximum Interlayer/1/4" Tempered Glass Frame: W-2172mm(85.50") H-2438mm(96") Sash: W-1021mm(40.19") H-827mm(32.56") DLO: W-933mm(36.75") H-708mm(27.88")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±5267 Pa (±110 psf) Water Penetration Resistance Test: 790 Pa (16.50 psf) Small Missile Impact Rated

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL-05108
Expiration Date: July 31, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com