

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015382.05
DATE: 07/27/2022
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing 24-36 Fadem Road Springfield, New Jersey 07081	Series "3800-3900/3800-3900" Vinyl Single Hung STD Muller Over Fixed Window Configuration: O/X/O Glazing: Insulated Glass (Annealed) Frame: W-914mm(36") H-2248mm(88.50") Sash: W-838mm(33") H-781mm(30.75") DLO: W-794mm(31.25") H-721mm(28.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 914 x 2248* (36 x 89*)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 11552.04-106-12/1687.02-106-12/1687.05-106-12
Expiration Date: **June 30, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com