

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015616.04  
DATE: 07/11/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Croft  
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Croft, LLC</b> <b>1800 North Clark Avenue</b> <b>Magnolia, MS 39652</b>	<b>Series "20W"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1829mm(72") Sash: W-846mm(33.31") H-892mm(35.13") DLO: W-775mm(30.5") H-819mm(32.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG50 914 x 1829* (36 x 72*)-H</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: B6276.03-801-47 (Specimen 2)/B6276.01-801-47  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)