

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015616
DATE: 07/11/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "20W" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2134mm(84") Sash: W-1149mm(45.25") H-1045mm(41.13") DLO: W-1080mm(42.5") H-972mm(38.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG20 1219 x 2134 (48 x 84)-H Design Pressure: ±960 Pa (20 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)

Product Tested By: Architectural Testing, Inc.
Report No: B6276.01-801-47
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com