

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015617  
DATE: 07/12/2022  
CERTIFICATION PROGRAM: Structural  
COMPANY: Croft  
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Croft, LLC</b> <b>1800 North Clark Avenue</b> <b>Magnolia, MS 39652</b>	<b>Series "30"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1207mm(47.5") H-1816mm(71.5") Sash: W-1146mm(45.13") H-762mm(30") DLO: W-1080mm(42.5") H-946mm(37.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG25 1207 x 1816 (48 x 72)-H</b> <b>Design Pressure: ±1200 Pa (25 psf)</b> Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: D0949.01-801-44  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)