## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** <u>NI015618</u>

**DATE:** 07/12/2022

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Croft

**CODE:** <u>1887-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC	Series "30W"
1800 North Clark Avenue	Vinyl Single Hung Window
Magnolia, MS 39652	
	Configuration: O/X Glazing: Insulating Glass (Annealed)
	Frame: W-1118mm(44") H-2134mm(84")
	Sash: W-1049mm(4131") H-1046mm(41.19")
	DLO: W-987mm(38.88") H-973mm(38.31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1118 x 2134 (44 x 84)-H
	Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf)

Product Tested By: PRI Construction Materials Technologies, LLC

Report No: 2189T0019 Expiration Date: **July 31, 2026** 

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com