

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015621  
**DATE:** 07/12/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Croft  
**CODE:** 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Croft, LLC</b> <b>1800 North Clark Avenue</b> <b>Magnolia, MS 39652</b>	<b>Series "95ES"</b> <b>Aluminum Single Hung Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1829mm(72") Sash: W-876mm(34.5") H-927mm(36.5") DLO: W-826mm(32.5") H-845mm(33.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG40 914 x 1829* (36 x 72*)-H</b> <b>Design Pressure: ±1920 Pa (40 psf)</b> Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: D0128.01-801-44/B3404.01-801-47  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)