

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015630  
**DATE:** 07/13/2022  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Croft  
**CODE:** 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Croft, LLC</b> <b>1800 North Clark Avenue</b> <b>Magnolia, MS 39652</b>	<b>Series "75/95"</b> <b>Aluminum Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1448mm(57") H-1448mm(57") DLO: W-1391mm(54.75") H-1403mm(55.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG50 1448 x 1448 (57 x 57)-FW</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2189T0008.02  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)