

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015633
DATE: 07/13/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Hi-Tech Energy
CODE: 2826-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hi-Tech Energy Windows, LTD. 1530 Erin Street Winnipeg, Manitoba, Canada R3E 2T	Series "Supercore 11200" Vinyl Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-813mm(32") H-1524mm(60") Vent: W-768mm(30.25") H-1473mm(58") DLO: W-629mm(24.75") H-1334mm(52.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG80 813 x 1524 (32 x 60)-C Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: I2582.02-901-44
Expiration Date: **July 31, 2025**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com