

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015641-R1
DATE: 07/19/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Moss Supply
CODE: 206-1
REVISION DATE: 10/04/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "3400" Vinyl Twin Single Hung Window Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-1816mm(71.50") Sash: W-848mm(33.38") H-892mm(35.13") DLO: W-789mm(31.06") H-819mm(32.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1816 x 1816 (72 x 72)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, LLC
Report No: N0292.01-501-44
Expiration Date: **December 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com