

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015647
DATE: 07/26/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "EDGE s " Thermally Broken Aluminum Sliding Glass Door Configuration: OIXX Glazing: Insulating Glass (Tempered) Frame: W-7309mm(287.75") H-3658mm(144") Panel: W-2442mm(96.13") H-3551mm(139.81") DLO: W-2419mm(95.25") H-3519mm(138.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class R-PG20 7309 x 3658 (288 x 144)-SD Design Pressure: ± 960 Pa (± 20 psf) Canadian Air Infiltration/Exfiltration Level: A2 Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf) - (with weather-stripping) Water Penetration Resistance Test Pressure: 290 Pa (6.00 psf) - (with weather-stripping and finish floor at same level as threshold) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) - (w/ weather-stripping and finish floor 0.875" higher than threshold)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T21-073
Expiration Date: July 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com