

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015648
DATE: 07/26/2022
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series “EDGE f ” Thermally Broken Aluminum Fixed Window (w/Butt Glazed Center) Configuration: OO Glazing: Insulating Glass (Tempered) Frame: W-3658mm(144") H-3048mm(120") DLO: W-1772mm(69.75") H-2921mm(115")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG30 3658 x 3048 (144 x 120)-FW Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T20-117
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com