NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI015650
DATE: 07/27/2022
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC **1800 North Clark Avenue** **Magnolia, MS 39652**	**Series "20W"** **Vinyl Single Hung Window** Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Sash: W-832mm(32.75") H-729mm(28.69") DLO: W-762mm(30") H-965mm(38")

SPECIFICATION	PRODUCT RATING
AAMA 1701.2-95/02 **Federal Manufactured Home Construction & Safety Standard 3280.305** **(applicable sub-sections)**	**Manufactured Housing-Passed** **Wind Zone III** **Design Wind Pressure Rating:** **+58/-58 psf**

Product Tested By: Intertek, PLC
Report No: F5242.01-801-44
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com