

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015657
DATE: 07/27/2022
CERTIFICATION PROGRAM: MFG HSG
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "4400W" Aluminum Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Sash: W-854mm(33.63") H-752mm(29.63") DLO: W-800mm(31.5") H-987mm(38.88")

SPECIFICATION	PRODUCT RATING
AAMA 1701.2-95/02 Federal Manufactured Home Construction & Safety Standard 3280.305 (applicable sub-sections) AAMA 1704-85/01	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf Egress - Passed

Product Tested By: Architectural Testing, Inc.
Report No: B7505.02-801-47
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com